

CITY COUNCIL AGENDA
Tuesday, September 21, 2004 7:30 PM

ADDENDUM NO. 1
to Regular Meeting

MEETING LOCATION: PASO ROBLES LIBRARY/CITY HALL
CONFERENCE CENTER, 1000 SPRING STREET

Revise item:

DISCUSSION

16. Code Amendment – Fire Sprinkler Requirement

R. Lata, Community Development Director

Consider amending Municipal Code Sections 17.04.020 and 17.04.030 (Uniform Building and Fire Code) reducing the requirement to install fire sprinkler systems in buildings greater than 5000 square feet. (Property at issue is at 1529 North River Road, a 1500-square foot addition to an existing building of approximately 6500-square feet. In 1988, the City amended the Uniform Building and Fire Codes requiring new construction in excess of 5000 square feet to be equipped with fire sprinklers. An amendment to the current code requirement is a procedural alternative to complying with the City's Code.)

OPTIONS:

- a. Reject the proposed code amendment, maintaining the current requirements for fire sprinklers.
- b. Approve a code amendment, based on the attached Exhibit "A", directing staff to modify the amendments to the Uniform Building and Fire Codes and reintroduce the codified amendment at the October 19, 2004 meeting for its first reading.
- c. Amend, modify, or reject the foregoing option.

ROLL CALL VOTE

*** End of Addendum ***